

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
 Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2017/SZ/ 567

Dated: 20/4/17.

FIRE SAFETY CERTIFICATE

Certified that the **Chinmaya Vidyalaya** located at **Vasant Vihar, New Delhi-110057**, comprised of two blocks, New Block- Basement (sunken), Ground + three upper floors & Old block- Ground + three upper floors, having total 147 rooms (124 class rooms, 11 office, 05 staff room, 05 laboratory and 02 library) was granted FSC by this department vide letter No. F.6/DFS/MS/School/2014/SZ/998 Dated 08/08/2014. The said premises was re-inspected by officer concerned of this department on 19-04-2017 in the presence of Mr. KR Nair (School Administrator) of the school and found that said school building have deemed complied with the fire prevention and fire safety arrangements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from 19/4/2017 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/4/17....at New Delhi by

Vipin Kental
 (Vipin Kental)
 Chief Fire Officer

Copy to: -

1. The Principal, Chinmaya Vidyalaya, Vasant Vihar, New Delhi-110057
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

